

Technical Support and E-Warranty Certificate www.vevor.com/support

VACUUM PUMP

MODEL:RS-1 / RS-1.5 / RS-2 / RS-3 / RS-6 2RS-2 / 2RS-3 / 2RS-4 / VP280

We continue to be committed to provide you tools with competitive price.

"Save Half", "Half Price" or any other similar expressions used by us only represents an estimate of savings you might benefit from buying certain tools with us compared to the major top brands and does not necessarily mean to cover all categories of tools offered by us. You are kindly reminded to verify carefully when you are placing an order with us if you are actually saving half in comparison with the top major brands.



VACUUM PUMP

MODEL:RS-1 / RS-1.5 / RS-2 / RS-3 / RS-6/2RS-2 / 2RS-3 / 2RS-4 / VP280



NEED HELP? CONTACT US!

Have product questions? Need technical support? Please feel free to contact us:

Technical Support and E-Warranty Certificate www.vevor.com/support

This is the original instruction, please read all manual instructions carefully before operating. VEVOR reserves a clear interpretation of our user manual. The appearance of the product shall be subject to the product you received. Please forgive us that we won't inform you again if there are any technology or software updates on our product.

SAFETY INSTRUCTION

Before operating this appliance, please read the instructions manual carefully and save these instructions. Basic safety precautions should always be followed, including the following:



Warning - To reduce the risk of injury, the user must read the instructions manual carefully.ed



This symbol, placed before a safety comment, indicates a kind of precaution, warning, or danger. Ignoring this warning may lead to an accident. To reduce the risk of injury, fire, or electrocution, please always follow the recommendation shown below.



WARNING

Household Use Only.

WARNING: Hot Surface-To reduce the risk of burns, do not touch.

CAUTION: To reduce the risk of electric shock, do not expose to rain. Store indoors.

CAUTION: To reduce the risk of electric shock, use indoors only.

WARNING: Risk of injury-Do not direct air steam at the body.

Utilisez seulement des menages.


AVERTISSEMENT: Surface chaude-Pour reduire le risque de brolures, ne touchez pas.

ATTENTION: Pour reduire le risque de choc electrique, ne pas exposer a la pluie.

Stockez indoorsduce100

ATTENTION: Pour reduire le risque de choc electrique, utilisez uniquement a linterieur. AVERTISSEMENT:RIsque de blessure-Ne pas courant dair directe sur le corps.

PUMP COMPONENTS



OPERATING MANUAL

1.Before using your vacuum pump

In all cases, motors are designed for operating voltages plus or minus $1\,0\,\%$ of the normal rating. Single voltage motors are supplied fully connected and ready to operate.

- (1) Check to be sure the voltage and frequency at the outlet match the specifications on the pump motor decal. Check the ON-OFF switch to be sure it is in the OFF position before you plug the pump into an outlet. Remove and discard the exhaust cap from the end of the pump's handle.
- (2) The pump is shipped without oil in the reservoir. Before starting the pump, fill it with oil. Remove the Exhaust Fitting cap and add oil until the oil just shows in the bottom of the sight glass. The approximate oil capacity of the pump is $1.80 \sim 8.00$ ml(reference the technical data).
- (3) Replace the Exhaust Fitting cap and remove the cap from one of the inlet ports. Turn the motor switch to ON. When the pump runs smoothly, replace the cap on the inlet port. This may take from two to 3 0 seconds, depending on the ambient temperature. After the pump runs for approximately one minute, check the sight glass for the proper oil level. The level should be even with the sight glass oil level line. Add oil if necessary.

Note: When the pump is running, the oil level should be even with the line on the sight glass. Underfilling will result in poor vacuum performance. Overfilling can result in oil blowing from the exhaust.

2.To shut down your pump after use

To help prolong pump life and promote easy starting. Follow these procedures for shut down.

- (1) Close the manifold valve between the pump and the system.
- (2) Remove the hose from the pump inlet.
- (3) Cap the inlet port to prevent any contamination or loose particles from entering the port.

TO MAINTAIN YOUR HIGH VACUUM PUMP

1.Vacuum pump oil:

The condition and type of oil used in any high vacuum pump are extremely important in determining the ultimate attainable vacuum. We recommend the use of High Vacuum Pump Oil. This oil has been specifically blended to maintain maximum viscosity at normal running temperatures and to improve cold weather starts.

2.0il Change Procedure

- (1)Be sure the pump is warmed up.
- (2)Remove the OIL DRAIN cap. Drain contaminated oil into a suitable container and dispose of it properly. Oil can be forced from the pump by opening the inlet and partially blocking the exhaust with a cloth while the pump is running. Do not operate the pump for more than 20 seconds using this method.
 - (3) When the flow of oil has stopped, tilt the pump forward to drain residual oil.
- (4)Replace the OIL DRAIN cap.Remove the exhaust fitting and fill the reservoir with new vacuum pump oil until the oil just shows at the bottom of the sight glass. The approximate oil capacity of the pump is 180-800ml(reference the technical data).
- (5)Be sure the inlet ports are capped, then turn on the pump. Allow it to run for one minute, then check the oil level space. If the oil is below the sight glass OIL LEVEL line, add oil slowly (with the pump running)until the oil reaches the OIL LEVEL line. Replace the exhaust fitting, making sure the inlet is

(6)

a)If the oil is badly contaminated with sludge that forms when water is allowed to collect in the oil, you may need to remove the oil reservoir cover and wipe it out.

b)Another method of dealing with heavily contaminated oil is to force the oil from the pump reservoir. To do this, allow the pump to run until it is warmed up. While the pump is still running, remove the oil drain cap. Slightly restrict the exhaust. This will backpressure the oil reservoir and force the oil from it, carrying more contamination. When the oil ceases to flow, turn off the pump.

Repeat this procedure as required until the contamination is removed.

Replace the OIL DRAIN cap and refill the reservoir to the proper level with fresh pump oil.

TROUBLESHOOTING GUIDE

Your pump has been for dependable use and has a long life. If something should go wrong, the following guide will help you get the pump back into service as quickly as possible.

If the disassembly of the pump is required, please check your warranty. The warranty may be voided by misuse or customer tampering, which results in the pump being inoperable.

1.Failure To Start

Check the line voltage. The pump needs to start at±10% line voltage (loaded) at 320F.At extremes,switching between the standard run windings may occur.

2.Oil leakage

- (1)Be sure the oil is not a residual accumulation from spillage, etc.
- (2)If leakage exists, the module cover gasket or the shaft seal may need replacing. If leakage exists in the area of the oil drain plug, you may need to reseal the plug using a commercial pipe thread sealer.

3. Failure To Pull A Good Vacuum

- (1)Be sure the vacuum gauge and all connections are in good condition and leak-free. You can confirm leakage by monitoring the vacuum with a thermistor gauge while applying vacuum pump oil at connections or suspected leak points.

 The vacuum will improve briefly while the oil is sealing the leak.
- (2)Be sure the pump oil is clean. A badly contaminated pump may require several oil flushes.
- (3)Be sure the oil is at the proper level. For maximum pump operation, the oil must be even with the OIL LEVEL line on the sight glass when the pump is running. Do not overfill—— operating temperatures will cause the oil to expand, so it will appear at a higher level than when the pump is not running. To check the oil level, start the pump with the inlet capped. Check the oil level in the sight glass. Add oil if necessary.

COMMON TROUBLE SHOOTING

Failure Description	Fault Cause	Solution
	1. The air inlet cap on the spare port side of the air inlet port is loose.	Tighten the air inlet cap
	2. The rubber ring inside the air inlet cap on the spare port side of the air inlet port is damaged	Replace the rubber ring
	3. Insufficient oil	Refuel to the centerline of the oil gauge
Low Vacuum	The pump oil is emulsified and unclean	Replace with new oil
	5. The oil inlet hole of the pump is blocked or the oil supply is insufficient	Clean the oil inlet hole and filter mesh
	6. Leakage of pipe container connected to the pump	Check the connected pipe container to prevent leakage
	7. Improper pump selection	Check the size of the pumped container, recalculate and select the appropriate pump model
	8. The pump has been used too long, and the clearance is increased due to the wear of parts	Check, repair, or replace the pump with a new one
	1. The oil seal is damaged	Replace the oil seal
Oil Leakage	2. The oil tank connection is loose or damaged	Tighten the screws and replace the O-ring
	1.Too much oil	Drain the oil to the oil level line
Oil Injection	2.The inlet pressure is too high for a long time	Select the appropriate pump to increase the pumping speed
Hard Starting	1. The oil temperature is too low	The air inlet is ventilated, repeatedly starts the motor or heats the pump oil
Tiald Starting	2. The motor or power supply is faulty	Check and repair
	3. Foreign objects fall into the pump	Check and eliminate
	4. The power supply voltage is too low	Check the power supply voltage

Note: If the above solutions do not solve your problem, please contact the nearest dealer, or send your pump to a professional repair center, and we will do our best to serve you.

TECHNICAL PARAMETER

SKU	3CFM1-3HPZKBOC001V2 3CFMZKB000000001V3
Model	RS-1
Voltage	220-240V 50Hz
Free Air Dispalcement	3CFM
Ultimate Vacuum	5PA
Rotating Speed	1440
Power (HP)	1/4
Oil Capacity (ml)	220
Dimension (mm)	240*110*220
Weight (Kg)	5

SKU	QCKTZKB2.5CFM1-4HV2
Model	RS-1
Voltage	220-240V 50Hz
Free Air Dispalcement	2.5CFM
Ultimate Vacuum	5PA
Rotating Speed	1440
Power (HP)	1/4
Oil Capacity (ml)	220
Dimension (mm)	240*110*220
Weight (Kg)	5

SKU	4.5CFM1-3HPZKB001V1
Model	RS-1.5
Voltage	120V/60HZ
Free Air Dispalcement	4.5CFM
Ultimate Vacuum	5PA
Rotating Speed	1720
Power (HP)	1/3
Oil Capacity (ml)	225
Dimension (mm)	270*110*220
Weight (Kg)	6

SKU	QCKTZKB5CFM1-3HPDV1
Model	RS-2
Voltage	120V/60HZ
Free Air Dispalcement	5CFM
Ultimate Vacuum	5PA
Rotating Speed	1720
Power (HP)	1/3
Oil Capacity (ml)	250
Dimension (mm)	290*120*240
Weight (Kg)	7

SKU	7CFM1-2HPZKB00001V1
Model	RS-3
Voltage	120V/60HZ
Free Air Dispalcement	7CFM
Ultimate Vacuum	5PA
Rotating Speed	1720
Power (HP)	1/2
Oil Capacity (ml)	250
Dimension (mm)	310*125*255
Weight (Kg)	7.5

SKU	7CFM1-2HPZKB00001V2
Model	RS-3
Voltage	220-240V 50Hz
Free Air Dispalcement	7CFM
Ultimate Vacuum	5PA
Rotating Speed	1440
Power (HP)	1/3
Oil Capacity (ml)	250
Dimension (mm)	310*125*255
Weight (Kg)	6.5

SKU	QCKTZKB6CFM1-2HP1V2
Model	2RS-2
Voltage	220-240V 50Hz
Free Air Dispalcement	6CFM
Ultimate Vacuum	0.3PA
Rotating Speed	2800
Power (HP)	1/2
Oil Capacity (ml)	330
Dimension (mm)	290*115*225
Weight (Kg)	10

SKU	QCKTZKB6CFM1-2HP1V1
Model	2RS-2
Voltage	120V/60HZ
Free Air Dispalcement	6CFM
Ultimate Vacuum	0.3PA
Rotating Speed	1400
Power (HP)	1/2
Oil Capacity (ml)	330
Dimension (mm)	290*115*225
Weight (Kg)	10

SKU	8CFM1HPZKB0000001V1
Model	2RS-3
Voltage	120V/60HZ
Free Air Dispalcement	8CFM
Ultimate Vacuum	0.3PA
Rotating Speed	3500
Power (HP)	3/4
Oil Capacity (ml)	370
Dimension (mm)	360*135*275
Weight (Kg)	11

SKU	8CFM1HPZKB0000001V2
Model	2RS-3
Voltage	220-240V 50Hz
Free Air Dispalcement	8CFM
Ultimate Vacuum	0.3PA
Rotating Speed	2800
Power (HP)	3/4
Oil Capacity (ml)	370
Dimension (mm)	360*135*275
Weight (Kg)	10

SKU	QCKTZKB7CFM1-2HPSV1
Model	2RS-3
Voltage	120V/60HZ
Free Air Dispalcement	7CFM
Ultimate Vacuum	0.3PA
Rotating Speed	3500
Power (HP)	3/4
Oil Capacity (ml)	370
Dimension (mm)	360*135*275
Weight (Kg)	10

SKU	9CF1HPZKBJB000001V3 9CF1HPZKBJB000001V2
Model	2RS-3
Voltage	220-240V 50Hz
Free Air Dispalcement	9CFM
Ultimate Vacuum	0.3PA
Rotating Speed	3500
Power (HP)	1
Oil Capacity (ml)	370
Dimension (mm)	360*135*275
Weight (Kg)	11

SKU	VP280ZKB00000001V3 VP280ZKB00000001V2
Model	VP280
Voltage	220-240V 50Hz
Free Air Dispalcement	10CFM
Ultimate Vacuum	0.3PA
Rotating Speed	2800
Power (HP)	1
Oil Capacity (ml)	550
Dimension (mm)	430*142*280
Weight (Kg)	19


SKU	VP280ZKB00000001V1
Model	VP280
Voltage	120V/60HZ
Free Air Dispalcement	12CFM
Ultimate Vacuum	0.3PA
Rotating Speed	3500
Power (HP)	1
Oil Capacity (ml)	550
Dimension (mm)	430*142*280
Weight (Kg)	19

SKU	QCK10CFM-220V9FSXV2
Model	2RS-4
Voltage	220-240V 50Hz
Free Air Dispalcement	10CFM
Ultimate Vacuum	0.3PA
Rotating Speed	2800
Power (HP)	1
Oil Capacity (ml)	550
Dimension (mm)	430*142*280
Weight (Kg)	19

SKU	12CFM1HPDJZKB0001V1
Model	RS-6
Voltage	120V/60HZ
Free Air Dispalcement	12CFM
Ultimate Vacuum	5PA
Rotating Speed	1720
Power (HP)	1
Oil Capacity (ml)	450
Dimension (mm)	430*140*250
Weight (Kg)	16.5

SKU	12CFM1HPSJZKB0001V2
Model	RS-6
Voltage	220-240V 50Hz
Free Air Dispalcement	12CFM
Ultimate Vacuum	5PA
Rotating Speed	1440
Power (HP)	1
Oil Capacity (ml)	450
Dimension (mm)	430*140*250
Weight (Kg)	16.5

EXPLODED DRAWING



1	Fan cover	24	Die-cast aluminum housing	
2	Cross screw	25	Sight glass	
3	Fan	26	Oil drain	
4	Motor cover	27	Oil drain screw O-ring	
5	Power supply cords	28	Screw	
6	Power switch	29	Sealing ring	
7	Washer	30	Screw	
8	Bearing	31	Rubber foot	
9	Motor rotor	32	Base plate	
10	Capacitor box	33	Self-tapping screw	
11	Centrifugal switch	34	Back-pump cover	
12	Motor stator	35	Oil seal	
13	Casing	36	Back-pump body	
14	Capacitor	37	Back-rotary -vane	
15	Handle	38	Back-pump rotor	
16	Trestle	39	Spring	
17	Gas cap	40	Middle fence	
18	The air inlet nozzle	41	Front-pump body	
19	Screw	42	Front- pump rotor	
20	Front rotary-vane	43	Front cover	
21	Spring	44	Oil seal	
22	Cap board	45	O type ring	
23	Exhaust and oil inlet fitting	46	Screw	

Manufacturer: WENLING HONGBAOSHI VACUUM EQUIPMENT CO.,LTD Address: Yaque Industrial Zone, Xinhe Town, Wenling City, Zhejiang Province



Technical Support and E-Warranty Certificate www.vevor.com/support

Made In China